



# NIPPON KAIJI KYOKAI

## *Certificate of Type Test*

Certificate No.  
TA22355M

MANUFACTURER: Mersen France SB SAS, France

PRODUCT: Low voltage HRC Fuse-links  
Cylindrical Fuse-links 10x38gG with or without indicator

TYPE NO.: FR10GG50V, FR10GG40V

TYPE TEST NO.: 07T101

PARTICULARS: Rated voltage a.c. 500V, 400V  
Rated current 2~25A at a.c.500V with indicator  
32A at a.c.400V with indicator  
0.5~25A at a.c.500V without indicator  
32A at a.c.400V without indicator  
Rated breaking capacity 120kA at a.c.500V, 400V

STANDARD: IEC60269-1 Ed.4.2(2014), IEC60269-2 Ed.5.1(2016)

DOCUMENTATION: A127844

THIS IS TO CERTIFY that the above mentioned product has been approved by the NIPPON KAIJI KYOKAI in accordance with the Society's type test requirements for electrical equipment and cables.

This certificate is valid until 26 September 2026.

Issued at Tokyo on 29 June 2022.

  
S. Oishi  
General Manager  
Machinery Department

